Report Date: 9/14/2022 **Report Time:** 4:00 PM EDT

Region II Hotline Log Entry Information

Data ID: 20729

Date Of Report: 6/17/2004 **NRC #:** 725301 **State #:** 0402890 **ERNS #:** 126752

Material Type: Oil Receiver: NORRELL

 Material / Amount:
 OTHER OIL / 171 GALLON(S)

 Location:
 Street:

City: TARRYTOWN
County: WESTCHESTER

State: NY Latitude: Longitude:

Source of Pollution: CON EDISON

Water Body: N/A
State Or EPA Responded: RP

Initial EPA Action: Contact RP to confirm cleanup completion

Status: URL:

Associated Action Reports

DataID: 0001973

ID: 0001775			
Date: 6/17/2004	Time: 14:37 EST	Time: 14:37 EST	
Duty Officer/Responder Name:	NRC Report #: 725301	Hotline Log DataID: 20729	
Action Information			
Description:			
Follup-Up:			
Person Contacted			
Name: Neil Norrell			
Organization: EPA-2			
Phone #• 732-321-4357			

NRC Spill Report

NATIONAL RESPONSE CENTER 1-800-424-8802

GOVERNMENT USE ONLYGOVERNMENT USE ONLY***

Information released to a third party shall comply with any

applicable federal and/or state Freedom of Information and Privacy Laws

Incident Report # 725301

INCIDENT DESCRIPTION

*Report taken by: CIV LOTTIE JOHNSON at 13:34 on 17-JUN-04

Incident Type: FIXED

Incident Cause: EQUIPMENT FAILURE

Affected Area:

The incident occurred on 16-JUN-04 at 12:05 local time.

Affected Medium: SOIL CONCRETE

REPORTING PARTY

Name: LARRY COSTA

Organization: CON EDISON

Address: 128 WEST END AVENUE

NEW YORK, NY 10023

CON EDISON called for the responsible party.

PRIMARY Phone: (212)5806763

INCIDENT LOCATION

150 WHITE PLAINS ROAD & MEADOW ST. County: WESTCHESTER

City: TERRYTOWN State: NY

VAULT 8671

RELEASED MATERIAL(S)

CHRIS Code: OTH Official Material Name: OTHER OIL

Also Known As: DIELECTRIC FLUID Qty Released: 171 GALLON(S)

CHRIS Code: PCB Official Material Name: POLYCHLORINATED BIPHENYLS

Also Known As:

Qty Released: 962 PART(S) PER MILLION

DESCRIPTION OF INCIDENT

MATERIAL RELEASED FROM A PAD MOUNTED TRANSFORMER DUE TO EQUIPMENT FAILURE.

SENSITIVE INFORMATION

INCIDENT DETAILS

Package: N/A Building ID:

Type of Fixed Object: TRANSFORMER Power Generating Facility: NO

Generating Capacity:

Type of Fuel: NPDES:

NPDES Compliance: UNKNOWN

IMPACT

Fire Involved: NO Fire Extinguished: UNKNOWN

INJURIES: NO Hospitalized: Empl/Crew: Passenger: FATALITIES: NO Empl/Crew: Passenger: Occupant:

EVACUATIONS: NO Who Evacuated: Radius/Area:

Damages: NO

Hours Direction of

<u>Closure Type</u> <u>Description of Closure</u> <u>Closed</u> <u>Closure</u>

Air: N

Road: N Major Art

Waterway: N Track: N

Passengers Transferred: UNKNOWN Environmental Impact: UNKNOWN

Media Interest: NONE Community Impact due to Material: NO

REPORTING PARTY

Type of Organization: PUBLIC UTILITY

SUSPECTED RESPONSIBLE PARTY

Name: LARRY COSTA
Organization: CON EDISON

Address: 128 WEST END AVENUE NEW YORK, NY 10023

PRIMARY Phone: (212)5806763

Type of Organization: PUBLIC UTILITY

REMEDIAL ACTIONS

CLEANUP COMPLETED
Release Secured: YES

Release Rate:

Estimated Release Duration:

WEATHER

Weather: CLEAR, 85@F

ADDITIONAL AGENCIES NOTIFIED

Federal:

State/Local: DEC, COUNTY DOH

State/Local On Scene:

State Agency Number: 0402890

NOTIFICATIONS BY NRC

ATSDR NJ ATTN: J. KOLAKOWSKI (PRIMARY) 17-JUN-04 13:39 (609)5887658

ATSDR NY (PRIMARY)

17-JUN-04 13:39 (212)6374307

U.S. EPA II (PRIMARY)

17-JUN-04 13:40 (732)3214370 MR. NORRELL

NOAA 1ST CLASS BB RPTS FOR NY (PRIMARY)

17-JUN-04 13:39 (206)5266344

BUREAU TOXIC SUBSTANCE R. WILBURN (PRIMARY)

17-JUN-04 13:39 (518)4027810 NY STATE DEC SPILL HOTLINE (PRIMARY)

17-JUN-04 13:39 (518)4577362

CTDEP OIL & CHEM SPILL RESP DIV (PRIMARY) 17-JUN-04 13:39 (860)4243338

NJ DEP POC: DUTY OFFICER (PRIMARY) 17-JUN-04 13:39 (609)5882848 ADDITIONAL INFORMATION

CALLER WILL UPDATE THE DEC, WESTCHESTER COUNTY DOH. AMOUNT OF MATERIAL RELEASED WAS BETWEEN 50-171 GALLONS.

*** END INCIDENT REPORT # 725301 ***

Report any problems or Fax number changes by calling 1-800-424-8802

PLEASE VISIT OUR WEB SITE AT http://www.nrc.uscg.mil